

**PREVENTIV**  
**Furnizim "Blerje pajisje per Nyjet Komutuese te Linjave dhe N.Stacioneve"**

Nr.	EMERTIMI	Njesia	Sasia	Cmimi/njesi	Vlera totale
				leke	leke
<b>1</b>	<b>Çelesa fuqie TL / TM</b>				
1.1	Çeles fuqie 110kV, me gas SF6, 1250A, 31.5kA Uop=220V DC	cope	2		
1.2	Çeles 110kV, me gas SF6, 1250A, 31.5kA Uop=110V DC	cope	2		
1.3	Çeles 40.5 kV, me gas SF6, 1250A, 31.5kA Uop=220V DC	cope	1		
1.4	Çeles 40.5 kV, me gas SF6, 1250A, 31.5kA Uop=110V DC	cope	1		
	<b>SHUMA 1</b>				
<b>2</b>	<b>Ndarësa fuqie TL / TM</b>				
2.1	Ndarës 110kV, me 1 ndarës toke , 1250A, 31.5kA, Uop=220V DC	cope	1		
2.2	Ndarës 110kV, me 1 ndarës toke , 1250A, 31.5kA, Uop=110V DC	cope	1		
2.3	Ndarës 110kV, me 1 ndarës toke , 1250A, 31.5kA, Uop=48V DC	cope	1		
2.4	Ndarës 40.5kV, me 1 ndarës toke , 1250A, 31.5kA, Uop=220V DC	cope	4		
2.5	Ndarës 40.5kV, me 1 ndarës toke , 1250A, 31.5kA, Uop=110V DC	cope	4		
2.6	Ndarës 40.5kV, me 1 ndarës toke , 1250A, 31.5kA Uop=48V DC	cope	1		

2.7	Ndarës 40.5kV, per linjat ajrore pozicion vertikal me 1 ndarës toke , 630A, 25kA,	cope	6		
<b>SHUMA 2</b>					
<b>3</b>	<b>Çela TM 40.5kV</b>				
3.1	Çela te kompletuara linje 40.5kV, 25kA, 630A, Uop=110V DC e pershtatshme per tu lidhur N.Stacionin Koplík 220/110/35/20kV, 300-600/1/1/1 A	cope	1		
3.2	Çela te kompletuara linje 40.5kV, 25kA, 630A, Uop=110V DC 300-600/1/1/1/1 A	cope	1		
3.3	Çela te kompletuara linje 40.5kV, 25kA, 630A, Uop=220V DC 300-600/1/1/1/1 A	cope	1		
3.4	Çela te kompletuara transformatori 40.5kV, 31.5kA, 1250A, Uop=110V DC 400-800/1/1/1/1 A	cope	1		
3.5	Çela te kompletuara transformatori 40.5kV, 31.5kA, 1250A, Uop=220V DC 400-800/1/1/1/1 A	cope	1		
3.6	Transformatore rryme per cela 40.5kV, 110V DC, 150-300/5/5/5 A	cope	30		
3.7	Transformatore rryme per cela 40.5kV, 110V DC, 300-600/5/5/5 A	cope	30		
<b>SHUMA 3</b>					
<b>4</b>	<b>Çela TM 24kV</b>				
4.1	Çela te kompletuara transformatori 24kV, 31.5kA, 1600A, Uop=220V DC, 800-1600/1/1/1/1 A	cope	4		
4.2	Çela te kompletuara transformatori 24kV, 31.5kA, 1600A, Uop=110V DC, 800-1600/1/1/1/1 A	cope	4		
4.3	Çela te kompletuara linje 24kV, 25kA, 630A, Uop=220V DC, 300-600/1/1/1/1	cope	9		
4.4	Çela te kompletuara linje 24kV, 25kA, 630A, Uop=110V DC 300-600/1/1/1/1	cope	15		
4.5	Çela te kompletuara matje 24kV, me Tr. Tensioni 20/0.1kV Uop=220V DC	cope	3		

4.6	Çela te kompletuara matje 24kV, me Tr. Tensioni 20/0.1kV Uop=110V DC	cope	3		
4.7	Transformatore tensioni te brendshem per cela 10kV, 10/0.1kV 100/√3;100/√3;100/3 V	cope	18		
4.8	Transformatore tensioni te brendshem per cela 6kV, 6/0.1kV 100/√3;100/√3;100/3 V	cope	18		
	<b>SHUMA 4</b>				
	<b>SHUMA ( 1 + 2 + 3 + 4 )</b>				
	<b>TVSH 20%</b>				
	<b>SHUMA TOTALE me TVSH</b>				